

## Legionnaires Disease Risk Assessment

Property address Abbey Church 3, The Highland Club, St. Benedict's Abbey, Fort Augustus

Date of assessment 8-11-22 Assessment carried out by M. DALLAS

Describe property type  
 Detached house  Single flat  Other

Is there any tenant, resident or regular visitor particularly susceptible to Legionella due to age, health or lifestyle?  
YES. ALL AGES STAYING.

Describe type of cold-water system e.g. mains feed or from storage tank  
 (Include sketch if possible at rear of document)  
MAINS FED.

Describe type of hot water system e.g. mains feed via combi boiler or from storage tank.  
 (Include sketch if possible at rear of document)  
MAINS FED VIA COMBI BOILER

### RISK CATEGORIES

#### 1. Water outlet temperature

Is cold water temperature at outlets below 20°C? Yes  No  Is the hot water temperature above 50°C at outlets? Yes  No

Cold water must flow from outlets at below 20°C & hot water above 50°C to minimise risk. If temperatures are too low/high then adjustments need to be made to the system i.e. lagging of pipework or adjustment of temperature settings for hot water.

Identify any Defect/Risk  
WATER COULD BE TURNED UP TOO HOT AT BOILER.

Related Recommendation  
PREVENT BOILER FROM EXCEEDING 60°C

Responsible person to carry out action  
 Landlord  Tenant  Other  Other Details: PROPERTY MANAGER

#### 2. Cold water storage tanks

Is there a cold water storage tank present? Yes  No  If No go to Q3 Does it have a tight fitting lid? Yes  No

Is the water temperature in the tank below 20°C? Yes  No  Is water in the tank clean & free of rust, debris, scale & organic matter? Yes  No

Is the tank insulated? Yes  No  Location of tank \_\_\_\_\_

If any debris etc. is present in the system it should be drained & thoroughly cleaned. If debris is from corrosion on the tank itself then the tank may need to be replaced. All cold water tanks should have tight fitting lids to prevent debris entering the system. Water in the tank should be below 20°C & the tank insulated to prevent the temperature rising above this level.

Identify any Defect/Risk

Related Recommendation

Responsible person to carry out action  
 Landlord  Tenant  Other  Other Details: \_\_\_\_\_

#### 3. Hot water

Is the temperature setting on the boiler and/or hot water tank such that the hot water is heated to and stored at a temperature of 60°C? Yes  No

*NB: If the temperature is set at above 60°C this can cause scalding to users. The temperature setting on the boiler and/or hot water tank should be set and maintained at 60°C.*

Identify any Defect/Risk  
BOILER COULD BE TURNED UP TOO HOT AT BOILER

Related Recommendation  
PREVENT BOILER FROM EXCEEDING 60°C

Responsible person to carry out action  
 Landlord  Tenant  Other  Other Details: PROPERTY MANAGER.

4. Little used outlets

Are there any water outlets that are used less than once per week e.g. in guest bathrooms? If yes, identify outlet & location below

Yes  No

Details POSSABILITY OF SHOWER OR TAPS IN GUEST ROOM NOT BEING USED

Any little used outlets should be flushed through weekly by running water through the outlet for at least 5 minutes. Aerosol production should be minimised during this process. It is better to run the water longer at a lower pressure to avoid aerosols.

Identify any Defect/Risk

LACK OF USE

Related Recommendation

CLEANERS TO FLUSH THROUGH AFTER EACH VISIT

Responsible person to carry out action

Landlord  Tenant  Other  Other Details: PROPERTY MANAGER

5. Shower heads

Are there any showers in the property? If yes, identify outlet & location below

Yes  No

ONE IN EACH BATHROOM

Details

Shower heads should be cleaned, disinfected and descaled at least once every 6 months. Aerosol production should be minimised during this process.

Identify any Defect/Risk

SHOWER HEADS

Related Recommendation

REMOVE WHEN NOT IN USE, DISINFECT TWICE YEARLY

Responsible person to carry out action

Landlord  Tenant  Other  Other Details: PROPERTY MANAGER

6. Dead legs and redundant pipework

Sections of pipework which are redundant or owing to the system design & have little/no through flow of water (known as "dead legs") can allow water to stagnate in the system. Are there any dead legs known in the system?

Are there any dead legs in the property? If yes, identify outlet & location below

Yes  No

Details

Any dead legs in pipework should be removed or the system altered so that water flows through all pipework regularly.

Identify any Defect/Risk

Related Recommendation

Responsible person to carry out action

Landlord  Tenant  Other  Other Details:

7. Unoccupied properties

Is the property left unoccupied for periods of time, e.g. in the case of student lettings over the summer holiday or at Christmas/New Year

Yes  No

All hot & cold water outlets should be flushed through at least once a week for at least 5 minutes when unoccupied & prior to re-occupation. Aerosol production should be minimised during this process. If empty long term - consider draining the system.

Identify any Defect/Risk

EMPTY PROPERTIES DURING QUIET PERIODS

Related Recommendation

FLUSH WEEKLY

Responsible person to carry out action

Landlord  Tenant  Other  Other Details: PROPERTY MANAGER

Advice to tenants (This can be done by giving the tenant/s the tenant advice sheet.)

Has advice been given to the tenants as to the risks of Legionnaires Disease in a domestic setting and their responsibilities to minimise risk?

Yes  No  N/A\*Short term lets

The assessment is complete and should be reviewed at least annually or if any information changes. You should ensure that the recommendations above are implemented and any existing controls maintained.

Signed

*[Signature]*

Date

8/11/22

Print Name

MARK DALCAS



SKETCH OF WATER SYSTEM 2 BED.  
MAINS FED COMBI BOILER.

